



GALE ASSOCIATES, INC.

Review is only for conformance with the design concept of the project and for compliance with the information given in the Contract Documents. The Contractor is responsible for dimensions and quantities to be confirmed and correlated at the site, for information that pertains to the fabrication process or to the means, methods, techniques, sequences and procedures of construction, and for the coordination of the work of all trades. The review and approval of a specific item shall not indicate approval of an assembly of which the item is a component.

- Approved
- Approved as Noted
- Revise and Resubmit
- Disapproved
- Received for Record

Submittal Number/Package 265668-1.2 Date Received 11/10/2021

Reviewed By Bree Sullivan Date Reviewed 11/19/2021

Section	Product	Status	Comment
26 56 68	Part 3 Pre-Packaged Sports lighting Systems	Received for Record	Manufacturer provided general lightning grounding diagram. Installation shall be as defined by NFPA 780 and be UL Listed per UL 96 and UL 96A in accordance with Section 3.5.C.9

*** All of the backup needs to be attached to the submittal stamp for record and future reference.

N:\715792\04 Construction\submittals\Submittal Review Stamp.docx

SPORTS LIGHTING POLE

TYPICAL GROUNDING

